

OFFICE USE ONLY  
 Log No. 42096  
 Permit No. \_\_\_\_\_  
 Basin 9-10B

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19143  
 ADDRESS AT WELL LOCATION 115 Hwy 95A North  
Yerington Nev 89447

1. OWNER William Cremetti  
 MAILING ADDRESS P.O. Box 443  
Yerington Nev 89447  
 2. LOCATION SW 1/4 SE 1/4 Sec. 21 T 14 S R. 25 E Lyon County  
 PERMIT NO. 14-241-01 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clayish		0	4	4
Coarse Sand & Gravel		4	19	15
Bluish Clay & Gravel		19	22	3
Bluish Sand & Gravel		22	32	10
Brown Sand & Gravel		32	56	24
Brown Clay & Gravel		56	59	3
Brown Sand & Gravel		59	90	31
Fill - Gravel & Small Rock		90	105	15
Brown Clay & Coarse Sand & Gravel		105	160	55
Brown Clay		160	175	15
Brown Coarse Sand & Gravel	X	175	196	21
Brown Clay & Coarse Sand		196	200	4

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 201'6" Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>71.5</u>	<u>200</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 3/32" 3" 6 Rows  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 105  
 Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 105 feet to 200 feet

9. WATER LEVEL  
 Static water level 23 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

Date started Oct 5, 1992  
 Date completed Oct 17, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>35</u>	<u>6'</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N. Bybee Lane Contractor  
Yerington Nev 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Jay Ogden  
 By driller performing actual drilling on site or contractor  
 Date 6-28-92