

OFFICE USE ONLY
 Log No. 42097
 Permit No. _____
 Basin 9-108

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Ralph Hiles ADDRESS AT WELL LOCATION Line
 MAILING ADDRESS 25 N. ByBee Lane
Yerington Nev 89447
 2. LOCATION NE 1/4 SE 1/4 Sec. 34 T. 14 S. R. 26 E. Lyon County
 PERMIT NO. 14-281-30 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Sandy		0	3	3
Sand - Gravel - Rock		3	24	21
Sand - Clay		24	26	2
Sand - Gravel		26	37	11
Sand - Gravel - Clay		37	39	2
Sand - Gravel		39	59	20
Sand - Gravel - Clay		59	70	11
Sand - Gravel		70	76	6
Sand - Clay		76	92	16
Sand - Gravel - Clay		92	104	12
Sand - Gravel		104	130	26
Clay - Sand - Gravel		130	140	10
Sand - Gravel		140	150	10
Coarse Sand - Gravel		150	157	7
Clay				
Coarse Sand - Gravel	X	157	177	20

8. WELL CONSTRUCTION
 Depth Drilled 177 Feet Depth Cascd 178 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 177
10 7/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>.188</u>	<u>71.5</u>	<u>4</u>
<u>6 5/8</u>		<u>.203</u>	<u>4</u>	<u>176.5</u>

Perforations:
 Type perforation jawed
 Size perforation 3 1/2" x 3" x 6 Rows
 From 156.5 feet to 176.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 176.5 feet

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Coden Bros Drilling Contractor
 Address 162 N ByBee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Lg Ogden
 By driller performing actual drilling on site or contractor
 Date 6-28-93

Date started Feb. 2, 1993
 Date completed Feb. 14, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>25</u>	<u>5</u>	<u>1/2</u>