WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42099
Permit No.
Basin 9-108

NOTICE OF INTENT NO. 19369

1. OWNER Bob Smith
MAILING ADDRESS 61 Hwy 208
Yerington Nev 89447

ADDRESS AT WELL LOCATION 611 Pete Henricks Road
Yerington Nev 89447

2. LOCATION SE ¼ SW ¼ Sec. 35 T. 14 N/S R. 26 E. Lyon County
PERMIT NO. (Issued by Water Resources) APN 04-141-09 (Parcel No.) #4 Hungry Horse Sub (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Coarse Sand, Gravel		2	10	8
Coarse Sand, Gravel + Rock		10	18	8
Coarse Sand, Gravel		18	58	30
Coarse Sand, Gravel + Rock		58	61	3
Coarse Sand, Small Gravel		61	77	16
Coarse Sand (Sed.)		77	85	8
Coarse Sand, Gravel Clay		85	89	4
Coarse Sand, Gravel		89	93	4
Coarse Sand Gravel Clay		93	95	2
Coarse Sand + Gravel		95	102	7
Coarse Sand, Gravel Clay		102	106	4
Coarse Sand Gravel		106	123	17
Clay + Coarse Sand		123	141	18
Coarse Sand Clay		141	157	16
Coarse Sand Small Gravel		157	160	3
Coarse Sand Clay		160	163	3
Clay		163	168	5
Coarse Sand + Small Gravel	X	168	180'3"	12'3"

Date started 8-10, 1992
Date completed 8-13, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailed	20	7	½ Hrs.

8. WELL CONSTRUCTION
Depth Drilled 180'3" Feet Depth Cased 181'3" Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	180'3"

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	180'3"

Perforations:
Type perforation Sawed
Size perforation 3/32 x 3" x 6 Rows
From 160'3" feet to 180'3" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 180'3" feet

9. WATER LEVEL
Static water level 113'6" feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bybee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Gary Ogden (By driller performing actual drilling on site or contractor)
Date 1-25-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627