

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22319

1. OWNER Round Mountain Gold Corp. ADDRESS AT WELL LOCATION mine site  
 MAILING ADDRESS P.O. Box 480 No physical address  
Round Mountain, Nv. 89045  
 2. LOCATION SE 1/4 NW 1/4 Sec 22 T. 10 N R. 43 E Nye County  
 PERMIT NO. M.D. 6267 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material            | Water Strata | From       | To         | Thick-ness |
|---------------------|--------------|------------|------------|------------|
| <u>FLUV</u>         |              | <u>0</u>   | <u>8</u>   |            |
| <u>Brown clay</u>   |              | <u>8</u>   | <u>15</u>  |            |
| <u>Gravel</u>       |              | <u>15</u>  | <u>17</u>  |            |
| <u>SAND</u>         |              | <u>17</u>  | <u>19</u>  |            |
| <u>Brown clay</u>   |              | <u>19</u>  | <u>32</u>  |            |
| <u>SAND</u>         |              | <u>32</u>  | <u>34</u>  |            |
| <u>Brown clay</u>   |              | <u>34</u>  | <u>38</u>  |            |
| <u>Gravel</u>       |              | <u>38</u>  | <u>45</u>  |            |
| <u>Brown clay</u>   |              | <u>45</u>  | <u>63</u>  |            |
| <u>Silty sand</u>   |              | <u>63</u>  | <u>70</u>  |            |
| <u>Black clay</u>   |              | <u>70</u>  | <u>74</u>  |            |
| <u>Gravel</u>       |              | <u>74</u>  | <u>77</u>  |            |
| <u>Brown clay</u>   |              | <u>77</u>  | <u>90</u>  |            |
| <u>Small gravel</u> |              | <u>90</u>  | <u>94</u>  |            |
| <u>Brown clay</u>   |              | <u>94</u>  | <u>102</u> |            |
| <u>Large gravel</u> | <u>✓</u>     | <u>102</u> | <u>116</u> | <u>14</u>  |
| <u>white clay</u>   |              | <u>116</u> | <u>120</u> |            |

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/4 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 120 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u>       |                     | <u>.188</u>             | <u>+2</u>   | <u>120</u> |

 Perforations:  
 Type perforation stainless steel screen  
 Size perforation 10 slot per inch  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow 40 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 58 °F Quality good

Date started 7-6 1993  
 Date completed 7-7 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M.    | Draw Down (Feet Below Static) | Time (Hours)  |
|-----------|-------------------------------|---------------|
| <u>40</u> | <u>N/A</u>                    | <u>4 hrs.</u> |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Woytek Drilling Co. Contractor  
 Address 2220 Stowe Dr. Contractor  
Reed, Nv. 89511  
 Nevada contractor's license number issued by the State Contractor's Board 24521  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442  
 Signed Les Woytek  
 By driller performing actual drilling on site or contractor  
 Date 7-22-93