

FOR USE ONLY
 Log No. 42127
 Permit No. 5-76
 Basin. 1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

BAD

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24047

1. OWNER Mick & Carol Rhodes ADDRESS AT WELL LOCATION 2000 View Court
 MAILING ADDRESS P.O. Box 1348 Fernley, NV 89408
 2. LOCATION SW 1/4 NW 1/4 Sec 36 T. 20 N. R. 25 E. Lyon County
 PERMIT NO. 21-307-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Gravel		2	26	24
Sand & Gravel		26	35	9
Gravel		35	163	128
Brown Clay		163	207	44
Gravel & Coarse Sand		207	230	23
Gravel & Brown Clay		230	255	25
Brown Clay		255	350	95
Black Volcanic Rock		350	410	60
Grayish Clay & Black Rock		410	460	50
Grayish Clay & Coarse Sand	X	460	520	60

JUL 30 A O 4?
 STATE ENGINEERS

8. WELL CONSTRUCTION
 Depth Drilled 520 Feet Depth Cascd 520 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8 Inches 0 Feet 520 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	520

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8"
 From 500 feet to 520 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 520 feet

9. WATER LEVEL
 Static water level 397 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne Post
 By driller performing actual drilling on site or contractor
 Date 7-13-93

Date started July 7, 1993
 Date completed July 12, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)



2100
23. 10. 3. 1944