



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23025

1. OWNER Pamela & Trent Patton ADDRESS AT WELL LOCATION 2210 Bullette
 MAILING ADDRESS 9410 N Virginia 2210 Bullette
Reno, Nv 89506 Lot 63 and 64 Block G

2. LOCATION NW SE 32 T 18 N/S R. 21 E Storey County
 PERMIT NO. 30061-31 Virginia City Highlands

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
Purple volcanic rock & clay mixture		1	30	29
Purple volcanic rock		30	125	95
Gray volcanic rock		125	150	25
Gray white specs purple white specs		150	170	20
purple white specs		170	185	15
Hard purple white specs & some multi-colored rock		185	216	31
T.D. 216 ft				

8. WELL CONSTRUCTION
 Depth Drilled 216 Feet Depth Cased 216 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 50
6 5/8 Inches. Feet. Feet
8 1/2 Inches. 50 Feet. 216 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	216

Perforations: factory
 Type perforation
 Size perforation 3/32 X 3
 From 196 feet to 216 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 216 feet

9. WATER LEVEL
 Static water level 58 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5/11/93 19____
 Date completed 5/12/93 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller.

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 5/13/93