

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23019

1. OWNER ASAP Pump & Well for Tom Otten ADDRESS AT WELL LOCATION: \_\_\_\_\_  
 MAILING ADDRESS 1800 1/2 Frazer / 3715 Warren 915 Shellbourne  
Sparks, Nv 89431 / Reno 89509 Lot 8 Block A  
 2. LOCATION SW 1/4 NW 1/4 Sec. 11 T. 18 N/S R. 19 E. Washoe County  
 PERMIT NO. 041-211-08 - Forest Hills  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cobbles & boulders		0	2	2
Brown clay & volcanic rock		2	20	18
Brown clay & volcanic sands & gravels		20	110	90
Volcanic sands & gravels & yellow & white clay		110	145	35
Volcanic sands & gravels yellow & white clay		145	155	10
Volcanic sands & gravels & brown clay		155	200	45
T.D. 200 feet				

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 200  
10 5/8 Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet  
 \_\_\_\_\_ Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	200

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3 double  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1804  
 Division of Water Resources, the on-site driller:  
 Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 5/19/93

Date started 4/30/93 19\_\_\_\_\_  
 Date completed 5/15/93 19\_\_\_\_\_  
 '93 JUL 19 PM 11:11 STATE ENGINEER

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>2</u>