

OFFICE USE ONLY  
 Log No. 42139  
 Permit No. \_\_\_\_\_  
 Basin 6-87  
 NOTICE OF INTENT NO. 21744

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Avis Andrulli ADDRESS AT WELL LOCATION 510 Zolezzi Ln  
 MAILING ADDRESS 510 Zolezzi Ln Reno NV 89511  
 2. LOCATION NE 1/4 NW 1/4 Sec. 20 T. 18 N/S R. 20 E Washoe County  
 PERMIT NO. 049-357-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	10	10
Gravel & coarse sands & clay		10	110	100
Volcanic gravels & coarse sands		110	168	58
Volcanic gravels & coarse sands & clay		168	198	30
T.D. 198 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 198 Feet Depth Cased 198 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 50 Feet  
 8 3/4 Inches 50 Feet 198 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	198

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 168 feet to 198 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 198 feet

9. WATER LEVEL  
 Static water level flowing feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11/3/92, 19\_\_\_\_\_  
 Date completed 11/5/92, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1 hr

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc Contractor  
 Address 625 Spice Islands Dr Suite L Contractor  
Sparks NV 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1132-T  
 Division of Water Resources, the on-site driller.  
 Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M Thrall 11/9/92