WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42142
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 20058

1. OWNER NEV-IDA PROPERTIES
MAILING ADDRESS 5270 Neil Road #203 Reno, Nv. 89502
ADDRESS AT WELL LOCATION Hacienda del Sol Restaurant, 2935 S. Virginia Street Reno, Nevada

2. LOCATION NE ¼ NW ¼ Sec. 24 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. M/O-593 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Plugged
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other ODEX

6. LITHOLOGIC LOG PLUGGING

Material	Water Strata	From	To	Thickness
Grey, v. hard River gravel & cobbles beneath 11.0' of Allite Type II Basecrock	X	11.0	34.2	23.2

*Note: James Oxley, Mike & I plugged the well today with 3.5 cubic feet of Basalite Type II Portland Cement from 8-9 am SMcD

Date started Plugging - July 15, 1993
Date completed Plugging - July 15, 1993

7. WELL TEST DATA N/A
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 34.2 Feet Depth Cased 34.2 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8 3/4	0	34.2

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	3/4 #	1/4 "	0	19.2

Perforations:
Type perforation .020 slotted PVC
Size perforation .020 slotted "
From 19.2 feet to 34.2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 14.0
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout & ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No #3 Lone Star
From 16.5 feet to 34.2 feet

9. WATER LEVEL
Static water level 26.0 feet below land surface
Artesian flow — G.P.M. P.S.I.
Water temperature 72 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor)
Address (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1655
Signed Scott B. McDaniel (By driller performing actual drilling on site or contractor)
Date July 15, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627