

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 42152  
 Permit No. \_\_\_\_\_  
 Basin. 7-92a

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23029

1. OWNER Byron Wholey  
 MAILING ADDRESS P. O. Box 60412  
Reno, Nv 89506

ADDRESS AT WELL LOCATION  
10175 Placerville Rd

2. LOCATION SE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Sec. 13 T. 21 N. R 18 E. Washoe County  
 PERMIT NO. 086-250-19 Silver Knolls

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC mud  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>tan clay with brown</u>				
<u>yellow green white</u>				
<u>D.G. sand zones</u>		<u>0</u>	<u>164</u>	<u>164</u>
<u>sticky tan clay</u>		<u>164</u>	<u>193</u>	<u>29</u>
<u>Coarse D.G. sands</u>				
<u>brown yellow green</u>				
<u>white</u>		<u>193</u>	<u>204</u>	<u>11</u>
<u>D.G. sand semi coarse</u>				
<u>tan clay</u>		<u>204</u>	<u>215</u>	<u>11</u>
<u>tan clay</u>		<u>215</u>	<u>237</u>	<u>22</u>
<u>brown yellow white</u>				
<u>green tan red coarse</u>				
<u>sands &amp; gravels</u>		<u>237</u>	<u>271</u>	<u>34</u>
<u>Sticky brown clay</u>		<u>271</u>	<u>278</u>	<u>7</u>
<u>T.D. 278 ft</u>				

8. 278 WELL CONSTRUCTION 278 Feet  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)  
 10 \_\_\_\_\_ Inches 0 \_\_\_\_\_ Feet 60 \_\_\_\_\_ Feet  
 8 3/4 \_\_\_\_\_ Inches 60 \_\_\_\_\_ Feet 278 \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 2</u>	<u>278</u>

Perforations: Factory  
 Type perforation \_\_\_\_\_  
 Size perforation 3/32 X 3  
 From 238 feet to 258 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 52 feet to 278 feet

9. 120 WATER LEVEL \_\_\_\_\_ feet below land surface  
 Static water level \_\_\_\_\_  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 6/1/93 19\_\_\_\_\_  
 Date completed 6/3/93 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>8/10</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AQUA DRILLING & WELL SERVICE, INC  
 Contractor  
 Address 625 SPICE ISLANDS DR SUITE L  
 Contractor  
SPARKS, NV 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources, the \_\_\_\_\_ site driller.  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
Roger M. Thrall 6/7/93  
 Date \_\_\_\_\_