WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42153
Permit No.
Basin 7-92a

NOTICE OF INTENT NO. 21664

1. OWNER NORMAN & DORIS BENNETT
MAILING ADDRESS P.O. Box 60716
Reno NV 89506

ADDRESS AT WELL LOCATION 10750 Outlaw
Reno, NV 89506

2. LOCATION NE ¼ SW ¼ Sec 24 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-203-08 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
BRown sandy clay		1	33	32
Green med. coarse sand		33	36	3
Brown sandy clay		36	59	23
Green sandy clay		59	111	52
Brown clay		111	163	52
Gray clay		163	207	44
Soft zone	X	207	216	9
Gray clay		216	227	11
Soft zone	X	227	235	8
Gray sandy clay		235	242	7

Date started 8-10-93, 19
Date completed 8-12-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 242 Feet Depth Cased 242 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 ½ Inches		50 Feet	242 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	242

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 197 feet to 237 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 242 feet

9. WATER LEVEL
Static water level 183 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary C. Fedman (By driller performing actual drilling on site or contractor)
Date August 13, 1993

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627