

OFFICE USE ONLY
 Log No. 42154
 Permit No. 7-92a
 Basin 7-92a
 NOTICE OF INTENT NO. 20027

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dave Keil ADDRESS AT WELL LOCATION 10155 Osage Court
 MAILING ADDRESS 954 Spice Islands Dr
Sparks, Nv 89431

2. LOCATION NE 1/4 SE 1/4 Sec. 25 T. 21 N/S R. 18 E. Washoe County
 PERMIT NO. 86-350-47 Silver Knolls
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
D. G. sand		0	2	2
Brown clay		2	5	3
D.G. sands		5	14	9
Tan clay sticky green yellow brown white sand zones		14	33	19
Green yellow brown white red sands with tan clay stringers		33	62	29
Green clay		62	81	19
Coarse green yellow brown white sands		81	87	6
Sticky tan clay		87	94	7
Brown green yellow white coarse sands & gravels		94	139	45
T.D. 139 ft				

8. WELL CONSTRUCTION
 Depth Drilled 139 Feet Depth Cased 139 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 139 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	139

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 119 feet to 139 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 53 feet to 139 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 6/3/93, 19____
 Date completed 6/4/93, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1 1/2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L Contractor
Sparks, Nv 89431

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 6/10/93