WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42158
Permit No.
Basin 7-92 b1

NOTICE OF INTENT NO. 21830

1. OWNER JERRY & CHAD LEGGETT
MAILING ADDRESS P.O. Box 1153
Anderson, CA 96007

ADDRESS AT WELL LOCATION 3425 Golden Valley Road
Reno, NV 89506

2. LOCATION SE ¼ SE ¼ Sec. 11 T. 20 N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 088-182-05 (Parcel No.) Golden Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Yellow-tan shail		1	18	17
Tan shail		18	58	40
Gray rock		58	77	19
Tan shail		77	85	8
Gray rock		85	104	19
Gray rock soft zone		104	108	4
Gray rock		108	152	44
Gray rock soft zone	X	152	170	18
Gray rock		170	205	35
Gray rock soft zone	X	205	208	3
Gray rock		208	220	12

'93 JUL 15 AM 11:14
STATE ENGINEER'S OFFICE

Date started 6-28-92, 19
Date completed 6-29-92, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 221 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	220	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.199	+1	220

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 133 feet to 173 feet
From 213 feet to 193 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. box 12370 (Contractor)
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 9, 1993

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

$\frac{1}{2}\alpha_1$

$\frac{1}{2}\alpha_1$