

OFFICE USE ONLY
Log No. 42169
Permit No. 8-101
Basin 1
NOTICE OF INTENT NO. 19/29

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Mack Rose ADDRESS AT WELL LOCATION 2675 ROGERS RD
MAILING ADDRESS 2675 ROGERS RD Fallon NV
2. LOCATION NW 1/4 SE 5 T. 18 S. R. 29 E. Church. 11 County Church. 11
PERMIT NO. 06-671-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand + Soil	NO	0	6	6
heavy sand	yes	6	10	4
Sand + clay	yes	10	15	5
Sand	yes	15	22	7
brn clay	NO	22	23	1

will deepen well
pull + clean casing
and install 25' seal

JUN -4 AM 11:14
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 23 Feet

HOLE DIAMETER (BIT SIZE)
From 10 Inches To 2.3 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>23</u>

Perforations:
Type perforation Torch cut
Size perforation 1/16" x 4"
From 10 feet to 22 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 10ft. Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 10 feet to 23 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature COLD °F Quality good

Date started 5/15 1993
Date completed 5/15 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10</u>	<u>10</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name E. A. Miller Contractor
Address P.O. 92 Contractor
SMITH, NV 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the driller 1806
Signed [Signature] # 1806
By driller performing actual drilling on site or contractor
Date 5/15/93