

OFFICE USE ONLY  
 Log No. 42182  
 Permit No. 8-101  
 Basin 8-101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2027

1. OWNER tony Kleeski's ADDRESS AT WELL LOCATION 1566 Allen  
 MAILING ADDRESS 1566 Allen Rd

2. LOCATION 11W 1/4 SE 1/4 Sec 35 T 19 N/S R 28 E Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand	X	0	16	16
clay		16	24	8
Silt	X	24	39	15
Black Clay		39	48	9
Black Silt	X	48	68	20
Grey Clay		68	79	11
Grey Sand	X	79	86	7
SAND	X	86	107	21

'93 AUG -6 AND '29  
 REGGIE D. ANDERSON  
 STATE ENGINEERS OF

8. WELL CONSTRUCTION  
 Depth Drilled 107 Feet Depth Cased 107 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 107 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.9</u>	<u>.188</u>	<u>41</u>	<u>107</u>

Perforations:  
 Type perforation Machine Slot  
 Size perforation .260

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 100 feet to 105 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 7-4-93 19\_\_\_\_  
 Date completed 7-4-93 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>1</u>

9. WATER LEVEL  
 Static water level 10' 8" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Woods Pflie Contractor  
 Address Box 888 Fallon Contractor

Nevada contractor's license number issued by the State Contractor's Board 1052  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed Woods Pflie by driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_