

OFFICE USE ONLY  
 Log No. 42185  
 Permit No. \_\_\_\_\_  
 Basin. B-10

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 24050

1. OWNER Helen Ellis ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 860 Gummow Drive 2215 Indian Lakes Road  
Fallon, NV 89406 Fallon, NV 89406  
 2. LOCATION NE SW 16 T 19 N 29 E Churchill County  
 PERMIT NO. 007-412-22 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	4	4
Brown Clay		4	8	4
Brown Coarse sand		8	16	8
Fine Brown Sand		16	29	13
Fine & Coarse Brown Sand		29	35	6
Black Clay		35	43	8
Black Coarse Sand		43	51	8
Black Clay		51	69	18
Green Clay		69	71	2
Black & Green Coarse Sand		71	86	15
Black & Green Clay		86	91	5
Black & Green Coarse Sand		91	96	5
Brown Coarse Sand		96	101	5
Brown Clay		101	103	2
Brown Fine Sand		103	117	14
Brown Coarse Sand	X	117	125	8

8. WELL CONSTRUCTION  
 Depth Drilled 125 Feet Depth Cased 125 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 125 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	125

Perforations:  
 Type perforation Mill Cut  
 Size perforation 1/8"  
 From 121 feet to 124 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 125 feet

9. WATER LEVEL  
 Static water level 25' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

Date started May 28, 1993  
 Date completed May 28, 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715  
 Signed Doug Parsons  
 By Driller performing actual drilling on site or contractor  
 Date June 18, 1993