WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42180
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 19363

1. OWNER Susan Lazicki
MAILING ADDRESS P.O. Box 107 Silver Springs Nev 89429
ADDRESS AT WELL LOCATION 6810 Redwood Silver Springs Nev 89429

2. LOCATION SE ¼ SE ¼ Sec. 12 T. 17 N S R. 24 E Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. 17-132-06 Subdivision Name Mountain View #3

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other unknown

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDON				
Knife casing		65'	3'	
3 Sides 5' Long				
Cuts				
Leave 1' Blank				
Between Cuts				
Casing in very				
Poor Shape				
old well				
Neat Cement				
Placed From				
65' To Surface				
No water Flowed				
From well				
28 Bags Pumped				

JUN 29 '93 P1:31 STATE ENGINEER'S OFFICE

Date started July 2, 19 92
Date completed July 2, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pump	5	9	15 min

8. WELL CONSTRUCTION
Depth Drilled — Feet Depth Cased 65' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
— Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.156	0	65'

Perforations:
Type perforation —
Size perforation —
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal —
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 51' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Bad

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Bibee Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 2, 92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627