

OFFICE USE ONLY  
 Log No. 42191  
 Permit No. \_\_\_\_\_  
 Basin 8-102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 22462  
 ADDRESS AT WELL LOCATION 7095 Elm St.  
Silver Springs, NV. 89429

1. OWNER Robert Collins ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 7095 Elm St. \_\_\_\_\_  
Silver Springs NV. 89429 \_\_\_\_\_  
 2. LOCATION NE 1/4 NE 1/4 Sec. 13 T. 17 N/S R. 24 E. Lyon County  
 PERMIT NO. 17-242-02 Parcel No. \_\_\_\_\_ Subdivision Name Pioneer  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other rod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand And Soil		0	25	25
Sand And Some Clay LT Brown		25	40	15
Clay Brown		40	52	12
Course Sand And Clay GRAY		52	70	18
Some Gravel and Course Sand Clay GRAY		70	95	25
Gravels		95	110	15
		110	140	30

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
11" Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13.00</u>	<u>3/16</u>	<u>1</u>	<u>140</u>

Perforations:  
 Type perforation HP Perf  
 Size perforation 1.8 x 1" x 5 ROWS  
 From 60 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-59  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60 feet to 140 feet

9. WATER LEVEL  
 Static water level 43 feet below and surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leads Drilling Contractor  
 Address Po Box 599 Silver Springs NV 89429 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877  
 Signed W. M. Lead By driller performing actual drilling on site or contractor  
 Date 6/23/14

Date started 6-1, 19 93  
 Date completed 6-2, 19 93

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Developed for 1 1/2 Hours</u>	<u>Produced about 35 Gallons</u>	<u>A min.</u>

JUN 23 2:43  
 RECEIVED  
 STATE ENGINEERS OFFICE