WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42192
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 22464

1. OWNER Mary Champlin
MAILING ADDRESS 8825 Karen
Silver Springs nv. 89429

ADDRESS AT WELL LOCATION 8825 Karen
Silver Springs, nv.

2. LOCATION SE ¼ SW ¼ Sec. 24 T. 17 N/S R. 24 E. Lyon County
PERMIT NO. 17-403-13 (Issued by Water Resources; Parcel No.) NA (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Soil		0	25	25
Course Sand And Silt		25	65	30
Fine Gravel and Course Sand		55	75	20
Clay Light Brown		75	95	20
Course Gravel	✓	95	109	14

'93 JUN 23 P 2:43
RECEIVED STATE ENGINEERS OFFICE

Date started 5-26, 19 93
Date completed 6-1, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Not Developed For 1½ Hours Produced 100 Gallons A min		

8. WELL CONSTRUCTION
Depth Drilled 109 Feet Depth Cased 109 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 5/8 Inches		0 Feet	109 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16	3/16	+1	109

Perforations:
Type perforation Torch Cut
Size perforation 1/8 x 6" x 5 Rows
From 89 feet to 109 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 109 feet

9. WATER LEVEL
Static water level 43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LEACH Drilling (Contractor)
Address PO Box 699 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1827
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/23/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627