

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10014

1. OWNER Bud Wycoff ADDRESS AT WELL LOCATION 8505  
 MAILING ADDRESS 8505 Santa Fe Stage Coach NV, 89429  
 2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 17 N/S R. 25 E Lyon County \_\_\_\_\_  
 PERMIT NO. N.A. Issued by Water Resources 15-432-24 Subdivision Name N.A.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil, Sand		0	12	12'
Sand, Gravels		12	80	68'
Gravels, Clay		80	99	19'
Grey Gravels, Clay	130	99	139	40'
Course Gravel	159	139	149	10'
Clay		149	159	10'

8. WELL CONSTRUCTION  
 Depth Drilled 159 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 159  
10 3/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1.88</u>	<u>0</u>	<u>159</u>

Perforations:  
 Type perforation Torch Cut  
 Size perforation 3/16 x 3 x 4 Downs  
 From 0 feet to 159 feet  
 From 99 feet to 119 feet  
 From 139 feet to 159 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 159 feet to up to 50 feet

9. WATER LEVEL  
 Static water level 86' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62 °F Quality Good

Date started 7/11/93 \_\_\_\_\_, 19\_\_\_\_  
 Date completed 7/13/93 \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>10-12</u>	<u>5</u>	<u>5 hrs</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling Inc Contractor  
 Address 26 599 Contractor  
Silver Springs NV, 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed Daniel Leach  
 By driller performing actual drilling on site or contractor  
 Date 7/13/93