

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 42205
 Permit No. 8-102
 Basin. 8-102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Guard L.T.D. ADDRESS AT WELL LOCATION 4905 Park St. Stagecoach, NV 89429
 MAILING ADDRESS 3130 Villa Marbella Cir. Reno, NV 89509-6602
 2. LOCATION NW 1/4 SE 1/4 Sec. 28 T. 18 N/S R. 24 E. Lyon County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand gravel + } cobblestone }		0	120	120
		120	238	118
Brown clay + } gravel }				
Brown Clay + } Some sand }		250	280	30
Coarse sand + } Brown clay }	X	280	340	60

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 3 3/4 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>340</u>

Perforations:
 Type perforation Mill
 Size perforation 18 x 3
 From 300 feet to 340 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 340 feet

9. WATER LEVEL
 Static water level 205 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 8-6 1993
 Date completed 8-10 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>30</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ACE Drilling and Development Contractor
 Address P.O. Box 668 Silver Springs, NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 70614299
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 706
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-10-93