WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42209
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 22460

1. OWNER Wallace A & Lorrine Davis
MAILING ADDRESS P.O. Box 294 Silver Springs, NV. 89429
ADDRESS AT WELL LOCATION Davis Road Silver Springs NV. 89429

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 18 N/S R. 25 E County
PERMIT NO. ~~#3 DOR, 70932~~ #3 DOR, 70932 (Issued by Water Resources) Parcel No. NA (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders And Gravels		0	30	30
Red Shale with Some Iron in it		30	160	130
Grayish Brown Shale	✓	160	197	97

Date started 6-4, 19 93
Date completed 6-7, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 3 Hours And Produced about 60+ Gallons A min		

8. WELL CONSTRUCTION
Depth Drilled 197 Feet Depth Cased 197 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 5/8	Inches	0	Feet	60	Feet
10"	Inches	60	Feet	197	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	16.00	3/16	+1	197

Perforations:
Type perforation torch cut
Size perforation 6 inch's long Diameter "Wide
From 4 Rows feet to feet
From 77 feet to 197 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 197 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Warm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address P.O. Box 599 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627