WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42210
Permit No.
Basin 8-102

NOTICE OF INTENT NO. 22548

1. OWNER Conrad & Rena Weismann
MAILING ADDRESS P.O. Box 363
Wadsworth, NV 89408

ADDRESS AT WELL LOCATION Hwy 95 Alt South
Fernley, NV 89408

2. LOCATION NW ¼ NW ¼ Sec 29 T 19 N/S X R 25 E Lyon County

PERMIT NO. (Issued by Water Resources) | Parcel No. 21-451-47 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	13	13
Black Volcanic Rock		13	160	147
Red Volcanic Rock		160	210	50
Brown Clay		210	230	20
Red Volcanic Rock		230	280	50
Yellowish Brown Clay		280	375	95
Red & Black Volcanic Rock		375	430	55
Red Volcanic Rock		430	695	265
Redish Volcanic Rock	X	695	705	10
Black & Red Volcanic Rock		705	720	15

Date started June 10, 19 93
Date completed June 19, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 720 Feet Depth Cased 720 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
6 Inches		60 Feet	720 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	60
4 1/2	11.35	.188	0	720

Perforations:
Type perforation Torch Cut
Size perforation 1/8"
From 705 feet to 720 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 650 feet to 720 feet

9. WATER LEVEL
Static water level 657 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-24-93

JUN 28 P 1:07 '93 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627