


Log No. 42217  
Permit No. \_\_\_\_\_  
Basin 162



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12046

1. OWNER James Hicks ADDRESS AT WELL LOCATION Kathryn St  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW 1/4 SW 1/4 Sec. 16 T. 19S N/S R. 53 E County NYE  
PERMIT NO. 24-271-07 Parcel No. \_\_\_\_\_ Subdivision Name Cowboy place II

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	6	6
caliche		6	8	2
Clay		8	14	11
caliche		14	22	3
Clay		22	31	9
caliche		31	35	4
Clay		35	52	17
caliche		52	55	3
Clay		55	72	17
Sand & gravel	WB	72	80	8
Clay		80	90	10
Sandstone	WB	90	97	7
Gravel	WB	97	100	13
Clay		116	128	18
caliche	WB	124	131	3
Gravel	WB	131	160	29

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 160 Feet  
Casing Schedule  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
2 3/4 16.44 .184 0 160  
Perforations:  
Type perforation Factory saw cut  
Size perforation 1/8 x 3/8  
From 120 feet to 140 feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 50  Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 160 feet

RECEIVED

AUG 02 1993

Div. of Water Resources  
Branch Office - Las Vegas, NV

Date started 7-6 1993  
Date completed 7-9 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
Static water level 69 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Great Basin Drilling Contractor  
Address Box 78 Boy 80358 Contractor  
Phamp NV 89041  
Nevada contractor's license number issued by the State Contractor's Board 35680  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 164  
Signed Thomas D...  
By driller performing actual drilling on site or contractor  
Date 7-13-93

