WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42242
Permit No.
Basin
NOTICE OF INTENT NO. 12048

1. OWNER Chuck Stevens
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 5 Dixie Road

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 21S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-253-16 (Parcel No.) Plantation Est (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Caliche		5	7	2
Clay		7	20	13
Caliche		20	23	3
Clay		23	36	13
Caliche		36	38	2
Clay		38	52	14
Caliche		52	54	2
Clay		54	61	7
Caliche	WB	61	63	2
Clay		63	79	16
Caliche	WB	79	84	5
Clay		84	93	9
Caliche	WB	93	95	2
Clay		95	102	7
Caliche	WB	102	104	2
Clay		104	113	9
Caliche	WB	113	117	4
Clay		117	121	4
Caliche	WB	121	123	2
Clay		123	130	7
Caliche	WB	130	140	10

Date started 7-26, 19 93
Date completed, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 24 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.44	.188	0	140

Perforations:
Type perforation Factory Sawcut
Size perforation 1/8 x 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 49 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HC2 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dunn (By driller performing actual drilling on site or contractor)
Date 8-13-93

I

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627