WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42298
Permit No.
Basin 212

NOTICE OF INTENT NO. 11565

1. OWNER NGWA
MAILING ADDRESS 6375 Riverside Dr. Dublin OH 43017

ADDRESS AT WELL LOCATION Riviera & Paradise

2. LOCATION NE ¼ SE ¼ Sec. 9 T. 21 N/S R. 61 E. Clark County

PERMIT NO. MO-2289 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	15	
Clay w/ Some Caliche		15	20	
Clay w/ Some Sands		20	40	

Well was abandon by removing casing & screen, pumping neat cement from bottom to top

Completed 5-27-93

RECEIVED
AUG 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 5-27, 1993
Date completed 5-27, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	40 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	PVC	Sch 40	0	20

Perforations:
Type perforation Slotted Screen
Size perforation .020
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 15
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 16 feet to 40 feet

9. WATER LEVEL
Static water level 22 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Environmental (Contractor)
Address 4301 S. Valley View #21 (Contractor)
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1487
Signed (By driller performing actual drilling on site or contractor)
Date 7-23-93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627