WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42345
Permit No.
Basin 162

NOTICE OF INTENT NO 2051

1. OWNER JOE DENNIS
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 82 FAIRBANKS ST PAHRUMP NV

2. LOCATION NW ¼ SW ¼ Sec 9 T 20S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 35-182-13 (Parcel No.) CAL VEGAS RANCHOS (Subdivision Name)

3. WORK PERFORMED
X ☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
X ☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable X ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY	0		8	8
CALICHIE		8	10	2
CLAY		10	20	10
CALICHIE		20	23	3
CLAY		23	36	13
CALICHIE		36	39	3
CLAY		39	48	9
CALICHIE		48	56	8
CLAY		56	61	5
CALICHIE	WB	61	63	2
CLAY		63	79	16
CAHICHIE	WB	79	82	3
CLAY		82	91	9
CALICHIE	WB	91	97	6
CLAY		97	100	3
CALICHIE	WB	100	102	2
CLAY		102	108	6
CALICHIE	WB	108	113	5
CLAY		113	125	12
CALICHIE	WB	125	128	3
CLAY		128	136	8
CALICHIE	WB	136	140	4
		140		140

Date started 8-4-93, 19
Date completed 8-6-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
SEP 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.25 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X ☐ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped X ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout X ☐ Concrete Grout

Gravel Packed: X ☐ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 47 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO INC (Contractor)
Address HCR 78 BOX 80358 (Contractor)
PAHRUMP NV 89041

Nevada contractor's license number issued by the State Contractor's Board. 30880
Nevada driller's license number issued by the Division of Water Resources, then-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 9-2-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627