



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2228

1. OWNER MARY BETZ ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ LOT 16 DOLLAR ST  
 \_\_\_\_\_ PAHRUMP NV 89041  
 2. LOCATION SE 1/4 Sec. 11 T21S N/S R53 E NYE County \_\_\_\_\_  
 PERMIT NO. 44-312-08 JOYCELYN ESTATES  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	6	3
CLAY		6	20	14
CALICHIE		20	23	3
CLAY		23	33	10
CALICHIE		33	36	3
CLAY		36	47	11
CALICHIE		47	52	5
CLAY		52	60	8
CALICHIE	WB	60	62	2
CLAY		62	69	7
CALICHIE	WB	69	71	2
CLAY		71	80	9
CALICHIE	WB	80	85	5
CLAY		85	93	8
CALICHIE	WB	93	96	3
CLAY		96	102	6
CALICHIE	WB	102	106	4
CLAY		106	110	4
CALICHIE	WB	110	113	3
CLAY		113	127	14
CALICHIE	WB	127	140	13
		140		140

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12.25 Inches \_\_\_\_\_ Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85 \ 8	16.9	.188	0	140

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1 \ 8 X 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. INC.  
 Contractor  
 Address HCR 78 BOX 80358  
PAHRUMP NV 89041  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1642  
 Division of Water Resources, the on-site driller  
 Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 4-3-93

Date started 8-26-93, 19\_\_\_\_  
 Date completed 8-28-93, 19\_\_\_\_

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED  
 SEP 13 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

