WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42357
Permit No.
Basin
NOTICE OF INTENT NO. 11420

1. OWNER Leo Roush
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5690 E. Manse Rd.

2. LOCATION SW ¼ SE ¼ Sec. 4 T. 21-S N/S R. 54 E Nye County
PERMIT NO. (Issued by Water Resources) 45-031-07 (Parcel No.) Christensen R.O.S. (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	18	14
Brown clay/gravel		18	21	3
Brown clay		21	46	25
Brown clay/gravel	X	46	92	46
Fine sand/gravel		92	114	22
Brown clay/gravel	X	114	125	11
Brown clay		125	140	15

RECEIVED
SEP 10 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started August 17, 19 93
Date completed August 17, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:
Type perforation Torch Cut
Size perforation ¼ in. width 8 in. long
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Pike Well Drilling (Contractor)
Address P. O. Box 56 (Contractor)
Pahrump, Nevada 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1324
Signed Jim Pike (By driller performing actual drilling on site or contractor)
Date August 25, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627