WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42364
Permit No.
Basin 164A

NOTICE OF INTENT NO. 11538

1. OWNER Steve Hedrick
MAILING ADDRESS 4193 Larkwood
Las Vegas, Nv. 89103

ADDRESS AT WELL LOCATION
Pacific & Alameda

2. LOCATION SW ¼ NE ¼ Sec. 26 T. 24 N/S R. 58 E. clark County
PERMIT NO. Issued by Water Resources | 580-611-002 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt sand & gravel		0	14	14
white clay & gravel		14	16	2
red clay & gravel		16	44	28
hard clay red & gravel		44	57	13
hard white clay		57	77	20
hard fractured red clay		77	150	73

RECEIVED
SEP 16 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-12, 19 93
Date completed 8-12, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	?	2

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	150 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1	150

Perforations:
Type perforation Torch
Size perforation 6" x 1/16" x 4 around
From 100 feet to 150 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. Contractor
Address 4847 So. Valley View Contractor
Las Vegas, Nv.
Nevada contractor's license number issued by the State Contractor's Board 0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661
Signed Donald L. Wolk
By driller performing actual drilling on site or contractor
Date 9-8-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627