

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 42372
 Permit No. _____
 Basin. 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18961

1. OWNER Janet Atkins ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SW 1/4 SE 1/4 Sec 26 T 19 N R 60 E Clark County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	15	15
Caliche		15	18	3
Clay		18	20	2
Caliche		20	26	6
Clay		26	140	114
Claystone	X	140	145	5
Clay		145	300	155
Claystone	X	300	340	40

8. WELL CONSTRUCTION
 Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 340 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>		

Perforations:
 Type perforation Joseph
 Size perforation 1 1/4" x 8"
 From 300 feet to 340 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 340 feet

9. WATER LEVEL
 Static water level 80' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 62.1 °F Quality OK

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mitchell Enterprises Contractor 
 Address 630 Ritz Contractor
Las Vegas NV 89124
 Nevada contractor's license number 27030
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1475
 Division of Water Resources, the on-site driller
 Signed Dean Mitchell
 By driller performing actual drilling on site or contractor
 Date 9-7-93

Date started 8-30 1993
 Date completed 9-6 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50-60</u>	<u>Wier pumped 2 hrs</u>	

RECEIVED
 SEP 9 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV