WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42402
Permit No.
Basin 212

NOTICE OF INTENT NO. 10554

1. OWNER Focus 2000
MAILING ADDRESS 4495 S. Polaris Ave
Las Vegas NV 89103

ADDRESS AT WELL LOCATION 3853 S. Highland Dr

2. LOCATION NW ¼ SW ¼ Sec. 17 T 21 ☒S R 61 E CLARK County
PERMIT NO. MO-2306A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger-H

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
Fill - Gravelly Sand	N	0	2	2
Caliche - brn	N	2	3	1
Sandy Clay - brn	N	3	6	3
SILTY CLAY - brn	N	6	13	7
SANDY CLAY - brn	Y	13	15	2
GRAVELLY CLAY - gray	Y	15	17	2
SILTY CLAY w/sand	Y	17	23	6

RECEIVED
FEB 01 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9/23, 1993
Date completed 9/23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 22½ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
8¼	0	23

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	22½

Perforations:
Type perforation slotted screen
Size perforation .010-inch
From 12.5 feet to 22.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 11 feet to 23 feet

9. WATER LEVEL
Static water level 13.82 feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature – °F Quality –

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim Atl c/o WTI (Contractor)
Address 3611 W. Tompkins Ave (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board –
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 141761
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/31/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42402
Permit No.
Basin 212

NOTICE OF INTENT NO. 10554

1. OWNER Focus 2000
MAILING ADDRESS 4495 S. Polaris Ave
Las Vegas, NV 89103

ADDRESS AT WELL LOCATION 3853 S. Highland Dr

2. LOCATION NW ¼ SW ¼ Sec. 17 T 21 ☒S R 61 E, CLARK County
PERMIT NO. MO-2306A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Augm-HSA

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
Fill - Gravelly Sand	N	0	2	2
Caliche - lt brn	N	2	3	1
Sandy Clay - brn	N	3	6	3
SILTY CLAY - brn	N	6	13	7
SANDY CLAY - brn	Y	13	15	2
GRAVELLY CLAY - gray	Y	15	17	2
SILTY CLAY w/sand	Y	17	23	6

RECEIVED
OCT 14 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9/23, 1993
Date completed 9/23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 22½ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8¼ Inches		0 Feet	23 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	22½

Perforations:
Type perforation slotted screen
Size perforation .010-inch
From 12.5 feet to 22.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 11 feet to 23 feet

9. WATER LEVEL
Static water level 13.82 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tim AE c/o WTI (Contractor)
Address 3611 W. Tompkins Ave (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board —
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9/27/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627