

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. #21544

1. OWNER Darrin Holly Holley ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 21660 Palamino Rd 900 Browning  
Reno, NV 89511 Reno, NV 89506  
 2. LOCATION SW SE 32 T 18N N 21 E Storey County  
 PERMIT NO. 03-081-14 Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil then Gray Clay with rock		0	17	17
Yellow Clay		17	35	18
Lt. Grey clay & rock		35	112	77
Lt. Purple rock		112	140	28
Grey/Blue Granite w/ Clay stringers & fractures		140	430	290
Blue/grey rock w/frac.		430	460	30
Hard Black rock	X	460	490	30

8. WELL CONSTRUCTION  
 Depth Drilled 490 Feet Depth Cased 490 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 3/4 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 490 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	490

Perforations:  
 Type perforation Factory  
 Size perforation .040 x 3"  
 From 240 feet to 260 feet  
470 feet to 490 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 490 feet

9. WATER LEVEL  
 Static water level 81 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality unknown

Date started 8-10, 1993  
 Date completed 8-31, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>		<u>2 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name MacKay Pump & Geothermal, Inc. Contractor  
 Address 1600 Mt, Rose Hwy Contractor  
Reno, NV 89511  
 Nevada contractor's license number 23096  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1788  
 Signed R. Bruce MacKay  
 By driller performing actual drilling on site or contractor  
 Date 8-31-'93

'93 SEP 14 AID:38  
 STATE ENGINEERS OF NEVADA