



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK **250BD**

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23028

1. OWNER Ed Dolak Sharon Boarts ADDRESS AT WELL LOCATION 5555 Twin Springs
 MAILING ADDRESS 5555 Twin Springs 25-2-1-9
Reno, Nv 89510
 2. LOCATION SE 1/4 NW 1/4 Sec. 25 T. 22 N/S R. 21 E. Washoe County
 PERMIT NO. 077-160-12 - Palomino Valley Unit 1
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown yellow red green volcanic sand and D.G.		0	22	22
Tan clay		22	35	13
Green clay stone		35	194	159
Black & green gravels		194	203	9
Sticky red brown clay		203	211	8
Black & dark green clay sticky		211	218	7
T.D. 218 ft.				

8. WELL CONSTRUCTION
 Depth Drilled 218 Feet Depth Cased 218 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 60
10 Inches Feet Feet
8 1/2 Inches 60 Feet 218 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2 1/2	218

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 158 feet to 178 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 53 feet to 218 feet

9. WATER LEVEL
 Static water level 7 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 5/26/93 19____
 Date completed 5/27/93 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AQUA DRILLING & WELL SERVICE, INC
 Contractor
 Address 625 SPICE ISLANDS DR SUITE L
 Contractor
SPARKS, NV 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 6/4/93