WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42469
Permit No.
Basin 6-85

NOTICE OF INTENT NO. 21700

1. OWNER Charles Smith
MAILING ADDRESS 37 S Tropicana Circle
Sparks, NV 89436

ADDRESS AT WELL LOCATION
Spanish springs Valley Ranches #2

2. LOCATION NE ¼ SW ¼ Sec. 14 T. 21 N/S R. 20 E/W Washoe County
PERMIT NO. 076-690-34 (Issued by Water Resources) Parcel No. Spanish Springs (Subdivision Name)

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
XX Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable XX Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Boulders		0	5	
Volcanic rock		5	8	
Brown clay & Sandstone		8	162	
Gray clay		162	191	
Brown DG		191	333	
Dark brown clay		333	436	
Gray sandstone		436	475	
Brown siltstone		475	517	
Red volcanic rock		517	545	
Brown siltstone	XX	545	725	

Date started 6-1-93, 19
Date completed 6-10-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump XX Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	18	700	2

8. WELL CONSTRUCTION
Depth Drilled 725 Feet Depth Cased 725 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	725 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14	.188	0	725

Perforations:
Type perforation Mechanical perforator
Size perforation 1/8 X 1
From 640 feet to 720 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: XX Yes ☐ No
Depth of Seal 50+
Placement Method: ☐ Pumped XX Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout XX Concrete Grout

Gravel Packed: XX Yes ☐ No
From 50 feet to 725 feet

9. WATER LEVEL
Static water level 560 feet below land surface
Artesian flow None G.P.M. None P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EMDLCO (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507

Nevada contractor's license number issued by the State Contractor's Board 32166

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Miller (By driller performing actual drilling on site or contractor)
Date 6-26-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627