

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23011

1. OWNER Stan Beni ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 12100 Mt Anderson # 31 Calle de la Plata (El Estero)
Reno, Nv 89506 Parcel C
 2. LOCATION SW 1/4 NE 1/4 Sec. 19 T. 21 N/S R. 21 E. Washoe County
 PERMIT NO. 076-371-91 372-05 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Over burden		0	1	1
D.G.		1	43	42
D.G. & volcanic rock		43	73	30
D.G. & mostly black volcanic rock		73	81	8
Black volcanic rock D.G. & little grey & rust colored clay		81	100	19
Granite		100	175	75
Hard colored granite & D.G.		115	150	35
Granite volcanic D.G. & clay		150	160	10
Granite & D.G.		160	175	15
Granite		175	260	85
Hard granite		260	518	258
Granite & D.G.		518	537	19
T.D. 536 ft				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188		

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 516 feet to 536 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 4 feet

9. WATER LEVEL
 Static water level 340 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 3/24/93

Date started 3/16/93, 19____
 Date completed 3/23/93, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15+</u>		<u>2</u>