WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42472
Permit No.
Basin Co-85

NOTICE OF INTENT NO. 23777

1. OWNER Annette Titus / Donna Davis
MAILING ADDRESS 4355 Wilcox Ranch Rd
Reno, Nv 89510

ADDRESS AT WELL LOCATION 510 Calle de la Plata
Parcel C Unit # 2

2. LOCATION NE ¼ SW ¼ Sec. 19 T. 21 N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 76-~~371-37~~ 572-11 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Volcanic cobbles with tan clay & D.G. sand		0	3	3
Brown yellow white semi decomposed granite		3	86	83
Black & white granite [hard]		86	342	256
Black & white granite with some green semi decomposed		342	528	186
T.D. 523 ft				

Date started 7/23/93, 19
Date completed 7/29/93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1½

8. WELL CONSTRUCTION
Depth Drilled 523 Feet Depth Cased 523 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	60
8 ½	60	523

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	523

Perforations:
Type perforation factory
Size perforation 3/32 X 3
From 483 feet to 503 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 57
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 57 feet to 523 feet

9. WATER LEVEL
Static water level 280 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L (Contractor)
Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 7/30/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627