

OFFICE USE ONLY
 Log No. 42475
 Permit No. _____
 Basin G-91

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21829

1. OWNER PETER STREMMEL ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1400 So Virginia Street Anitra Lot #2
Reno, NV 89503 Reno, NV 89511
 2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 18N. N/S R. 19 E Washoe County
 PERMIT NO. 041-290-16 SW Reno Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil with boulders		0	2	2
Gray volcanic rock		2	33	31
Brown volcanic rock		33	93	60
Purple volcanic rock		93	159	66
Brown volcanic rock		159	211	52
Yellow volcanic rock		211	290	79
Gray volcanic rock		290	344	54
Rusty brown volcanic rock		344	399	55
Soft zone	X	399	407	8
Brown volcanic rock		407	443	36
Soft zone	X	443	455	12
Gray volcanic rock		455	481	26
Soft zone	X	481	484	3
Gray volcanic rock		484	500	16

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 500 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	500

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 393 feet to 413 feet
 From 435 feet to 455 feet
 From 475 feet to 495 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 500 feet

193 SEP -7 P2:44
 RECEIVED
 STATE ENGINEERS OFFICE

Date started 8-23-93 19_____
 Date completed 8-25-93 19_____
 7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 347 feet below land surface
 Artesian flow 35 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 31, 1993