WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42478
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 24241

1. OWNER Central Enterprises
MAILING ADDRESS 3995 River Haven Reno NV. 89509
ADDRESS AT WELL LOCATION 12965 Mira Loma Reno NV.

2. LOCATION NE ¼ SE ¼ Sec. 17 T. 18 N/S R. 20 E. Washo County
PERMIT NO. Issued by Water Resources
Parcel No. 050-277-02
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Clay		6	17	11
Volcanic Gravels		17	45	28
1/4 Gravels		45	70	25
Brown Clay		70	100	30
Clays w/imbedded Volcanic Sands		100	137	37
Hard Volcanic Gravels	XXA	137	170	33

'93 SEP -2 P1:27
RECEIVED
STATE ENGINEERS OFFICE

Date started 8-21, 1993
Date completed 8-23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	50'	2

8. WELL CONSTRUCTION
Depth Drilled 170' Feet Depth Cased 170' Feet

HOLE DIAMETER (BIT SIZE)
11¼ Inches From 0 Feet To 170' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	170'

Perforations:
Type perforation Mill Shot
Size perforation 3½ X 3/32
From feet to feet
From 150' feet to 170' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100' feet to 170' feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Warm Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name
Contractor
Address
Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quinton R. Bulls
By driller performing actual drilling on site or contractor
Date 8/23/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627