

OFFICE USE ONLY  
 Log No. 47180  
 Permit No. 6-EP  
 Basin. 6-EP

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Dan Rasner Const. ADDRESS AT WELL LOCATION 865 Washoe Dr Carson City  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 SE 1/4 Sec 23 T 17 N R 19 E Washoe County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Granite sand course		0	40	40
Course granite sand Greenish clay streaks saturated	*	40	135	95

'93 SEP 10 P 1:58  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet  
135 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>135</u>

Perforations:  
 Type perforation Factory Milled  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 115 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51  Neat Cement  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 135 feet

9. WATER LEVEL  
 Static water level Apr 35' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold F Quality \_\_\_\_\_

Date started Aug 4 1993  
 Date completed Aug 5 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Enloe Drilling Contractor  
 Address P.O. Box 1345 Contractor  
Dayton, Nev  
 Nevada contractor's license number issued by the State Contractor's Board 4739A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480  
 Signed Loe A. Enloe  
 By driller performing actual drilling on site or contractor  
 Date 8-7-93