WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42483
Permit No.
Basin 6-89

NOTICE OF INTENT NO. 24221

1. OWNER Otis L. Turner
MAILING ADDRESS 4080 East Lake Blvd
Washo Valley
ADDRESS AT WELL LOCATION 105 Esmeralda
New Washo City

2. LOCATION SW ¼ SW ¼ Sec. 32 T. 17 N/S R. 20 E. Washo County
PERMIT NO. 57741 (Issued by Water Resources) 050-411-28 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Sand		4	22	18
Brown Clay		22	27	5
D.G. Sands		27	65	38
Hard D.G. Sand w Clayseams		65	95	30
Hard D.G.		95	107	12
Blue Granite		107	130	23
D.G.		130	157	27
Broken D.G. w/ Water	xxx	157	170	13
Hard Granite w/ Fractures	xx	170	200	30

Date started 8-20, 1993
Date completed 8-23, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		4

8. WELL CONSTRUCTION
Depth Drilled 200' Feet Depth Cased 200' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0' Feet	60' Feet
10 Inches	60' Feet	200' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200'

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From feet to feet
From 160 feet to 200' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 200' feet

9. WATER LEVEL
Static water level 60' feet below land surface
Artesian flow G.P.M. 12 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H PUMP CO. Contractor
Address 5551 Hwy 50 East
Carson City, Nevada
Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Anderson R. Bults
By driller performing actual drilling on site or contractor
Date 8/20/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627