WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42484
Permit No.
Basin 7-92a

NOTICE OF INTENT NO. 21839

1. OWNER RICK JAMESON
MAILING ADDRESS 10235 Shannandoah
Reno, NV 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NE ¼ Sec. 24 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-222-11 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Fill in bottom, brown sand		153	175	22
Blue clay		175	181	6
Med. coarse sands	X	181	196	15
Brown clay		196	201	5
Med. coarse sands	X	201	210	9
Brown clay		210	221	11
Soft zone-getting no return, had to stop drilling to soft of a material.		221	225	4

'93 SEP 13 P2:47
STATE ENGINEERS OFFICE

Date started 9-2-93, 19
Date completed 9-2-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6" Inches	153 Feet	225 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 160 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 150 feet to 225 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date September 8, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627