WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42485
Permit No.
Basin 7-92a

NOTICE OF INTENT NO. 21838

1. OWNER LEN & JULIE MONTGOMERY
MAILING ADDRESS P.O. Box 630, Verdi, NV 89439
ADDRESS AT WELL LOCATION 10825 Santa Fee, Reno, NV 89506

2. LOCATION NW ¼ NE ¼ Sec. 25 T 21N N/S R 18 E Washoe County
PERMIT NO. (Issued by Water Resources) 086-193-06 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Well have clay bottom	at 79 feet			
Brown sandy clay		79	88	9
Soft zone		88	91	3
Brown sandy clay		91	106	15
Brown sandy clay med/ coarse	X	106	117	11
Brown clay		117	122	5
Coarse sand		122	141	19
Brown sandy clay		141	145	4

RECEIVED 93 SEP -7 P2:44 STATE ENGINEERS OFFICE

Date started 8-26-93, 19
Date completed 8-26-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 66 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 3/4 Inches	79 Feet	145 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	145

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal N/A
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 79 feet to 145 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow 20 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 31, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627