

OFFICE USE ONLY
 Log No. 42491
 Permit No. _____
 Basin 7-97
 NOTICE OF INTENT NO. 25776

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Fish Springs Ranch ADDRESS AT WELL LOCATION Fish Springs Ranch
 MAILING ADDRESS Star Rt
Flanigan 89510

2. LOCATION SE $\frac{1}{4}$ SW $\frac{1}{4}$ Sec 10 T. 26 N/S R. 19 E. Washoe County
 PERMIT NO. 074-412-19 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--|--------------|------|-----|------------|
| Brown yellow green white orange gravels & sands coarse with tan clay | | 0 | 198 | |
| T.D. 192 ft | | | | |
| There is 6 feet of gravel fill from 192' to 198' | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 198 Feet Depth Cased 192 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 198
11 Inches Feet
 _____ Inches Feet
 _____ Inches Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 12.92 | .188 | + 2 | 192 |

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 158 feet to 178 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 53 feet to 192 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 7/15/93, 19_____
 Date completed 7/16/93, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| 20+ | | 2 |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number 1511
 issued by the Division of Water Resources, the on-site driller
 Signed R. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 7/20/93