

OFFICE USE ONLY  
 Log No. 42492  
 Permit No. \_\_\_\_\_  
 Basin 7-97  
 NOTICE OF INTENT NO. 23787

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Dr Harry Brown/ Fish Springs ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Star Rt 74071 Fish Springs Rd  
Flanigan, Nv 89510

2. LOCATION SW 1/4 SW 1/4 Sec 20 T 26 N/S R 19 E Washoe County  
 PERMIT NO. 74-070-72 - Fish Springs Ranch  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan clay & sand		0	17	17
Green yellow white red brown sands & gravels with tan clay		17	97	80
Hard dark green rock with some fractures		97	114	17
Red volcanic rock hard fractured		114	136	22
Red volcanic rock with red clay		136	150	14
Green volcanic rock hard fractured with traces of red clay & orange volcanic rock		150	235	85
Red volcanic rock with white specs, hard		235	258	23
T.D. 258 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 258 Feet Depth Cased 258 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 258 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+ 2	258

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 218 feet to 238 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 52  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 52 feet to 258 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started 7/19/93 19\_\_\_\_\_  
 Date completed 7/22/93 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2 1/2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
 Contractor  
Sparks, Nv 89431  
 Nevada contractor's license number 15291  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1511  
 Division of Water Resources the on-site driller  
 Signed Roger M. Thrall  
 By driller performing actual drilling on site or contractor  
 Date 7/26/93