WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42500
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 32575

1. OWNER Peachtree Properties
MAILING ADDRESS 710 W. Williams Avenue
Fallon, NV 89406

ADDRESS AT WELL LOCATION
2939 Woodlands Place
Fallon, NV 89406

2. LOCATION SW ¼ SE ¼ Sec. 6 T. 18 N/S R. 29 E. Churchill County

PERMIT NO. (Issued by Water Resources) | 006-741-53 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Coarse Brown Sand		5	18	13
Brown Clay		18	22	4
Coarse & Fine Sand	X	22	33	11

'93 SEP -1 A10:37
RECEIVED
STATE ENGINEERS OFFICE

Date started August 17, 1993
Date completed August 19, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 33 Feet Depth Cased 33 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	33 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	29

Perforations:
Type perforation Houston Removable Well Screen
Size perforation .20 Slot
From 28 feet to 33 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 25
Placement Method: [X] Pumped [ ] Poured
Seal Type: [XX] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 25 feet to 33 feet

9. WATER LEVEL
Static water level 7' 9" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date 9-25-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627