

OFFICE USE ONLY
 Log No. 42515
 Permit No. _____
 Basin 8-101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22756

1. OWNER Woodworm Const ADDRESS AT WELL LOCATION 2215 Coleman
 MAILING ADDRESS 221 Manchester

2. LOCATION SE 1/4 SE 1/4 Sec 26 T 19 N R 28 E Churchill County
 PERMIT NO. 08-351-21
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	15	15
fine silty sand	X	15	60	45
Black Clay		60	83	23
Grey Clay		83	88	5
Sand	X	88	110	22

8. WELL CONSTRUCTION
 Depth Drilled 110 Feet Depth Cased 110 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
6 Inches 50 Feet 110 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>127</u>	<u>.188</u>	<u>71</u>	<u>110</u>

Perforations:
 Type perforation Machinic Slot
 Size perforation .060
 From _____ feet to _____ feet
 From 100 feet to 106 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 11-9 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 54 °F Quality _____

Date started Sept 17 1993
 Date completed Sept 17 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Welsco Contractor
 Address Box 888 Contractor
Fallon NV
 Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed W.B. file
 By driller performing actual drilling on site or contractor
 Date Sept 21-93