WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42518
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 22586

1. OWNER Kelly Hyatt
MAILING ADDRESS P.O. Box 1059
Fallon, NV 89406

ADDRESS AT WELL LOCATION 5471 Riversedge Dr.
Fallon, NV 89406

2. LOCATION NW ¼ SW ¼ Sec. 29 T. 19 N/S R. 28 E. Churchill County

PERMIT NO. (Issued by Water Resources) 001-551-36 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	4	4
Brown Sand		4	25	21
Brown CLay		25	30	5
Brown Coarse Sand		30	35	5
Brown Clay		35	38	3
Fine Brown Sand		38	43	5
Gray Clay		43	54	11
Greenish COarse Sand		54	70	16
Fine Brownish Coarse Sand		70	125	55
Gray Sandy Clay		125	130	5
Grayish Sand		130	135	5
Gray Sandy Clay		135	139	4
Brown Sand		139	147	8
Brown CLay		147	153	6
Brown COarse Sand	X	153	166	13

'93 SEP -1 A10:37 RECEIVED STATE ENGINEERS OFFICE

Date started August 24, 19 93
Date completed August 25, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 166 Feet Depth Cased 166 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	166 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	161

Perforations:
Type perforation Houston Removable Well Screen
Size perforation .350
From 161 feet to 166 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 166 feet

9. WATER LEVEL
Static water level 14' 8" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date 8-25-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627