WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42527
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 22579

1. OWNER Justin Schnider
MAILING ADDRESS 3106 Bottom Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 3318 Bottom ROad
Fallon, NV 89406

2. LOCATION SE ¼ NE ¼ Sec 33 T. 19 N/~~S~~ R 28 E CHurchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 010-541-18 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Clay		10	17	7
Brown Sand		17	30	13
Brown Clay		30	32	2
Brown Sand		32	38	6
Fine Green Sand		38	57	19
Gray Clay		57	63	6
Coarse Brown Sand		63	65	2
Grayish COarse Sand		65	68	3
Brown Sand	X	68	84	16
Brown Clay		84	85	1

'93 SEP 15 A10:22
STATE ENGINEER'S OFFICE

Date started August 26, 19 93
Date completed August 26, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	85 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	81

Perforations:
Type perforation Removable Houston Well Screen
Size perforation .350
From 80 feet to 85 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 50 feet to 85 feet

9. WATER LEVEL
Static water level 5'7" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons (By driller performing actual drilling on site or contractor)

Date 9-7-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627