

OFFICE USE ONLY  
 Log No. 42530  
 Permit No. \_\_\_\_\_  
 Basin 8-101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22800  
70 Deer trail

1. OWNER Alkies Const ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2160 Rice Rd

2. LOCATION SE 1/4 SW 1/4 Sec 19 T. 17 N/S R. 29 E Churchill County  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Venturacci

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface Soil		1	3	3
Clay		3	10	7
Clay & Sand	X	10	30	20
Black Clay		30	41	11
Black Silt	X	41	68	27
Grey Clay		68	73	5
Clay		73	80	7
Gravel		80	85	5

8. WELL CONSTRUCTION  
 Depth Drilled 85 Feet Depth Cased 85 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 30 Feet  
6 Inches 50 Feet 85 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.7</u>	<u>.188</u>	<u>+1</u>	<u>85</u>

Perforations:  
 Type perforation Machine Slot  
 Size perforation .060  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 78 feet to 84 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 61 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welso Contractor  
 Address Box 888 Contractor  
Fallon Nev.  
 Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Sept 21

Date started Sept 20 1993  
 Date completed Sept 20 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		

'93 SEP 24 AM 11:42  
 STATE ENGINEER'S OFFICE